

Loose House Leakage Test Report #1

Report Prepared For: [REDACTED]
 Prepared By: Kevin C Martin, Summers & Zim's, Atglen, PA
 Date Of Test: October 6, 2020

Living Area: 3,000 square feet on 2 Story; 3 Bedrooms; 9 ft Avg. Ceiling Height
 Wind Shielding: Normal suburban (Wind Shielding Factor: 1)
 Climate: West Chester (LBL Climate Zone: 2)

Temperatures: Inside = 70°F, Outside = 58°F, Depressurize from inside
 Test Data: 25 pa House Pressure, 99 pa Flow Pressure on Ring A, 2,608 CFM

<i>Leakage Areas and Sealing Potential</i>	
Calculated Optimum Leakage Area:	1.65 square feet, 237.2 square inches
Measured Leakage Area:	3.36 square feet, 484.4 square inches
Total Leakage Area is equal to a crack half an inch high by 81 feet long.	
247 square inches can be sealed before reaching the Optimum Leakage Area.	

<i>Air Exchange Rates: Annual Average, Manual J and Mechanical</i>	
Estimated Annual Average Air Change Rate:	13.07 per day, 0.54 per hour
Estimated Manual J Air Change Rate: (C = 322 N = 0.650)	Winter = 0.68 per hour or 306 CFM Summer = 0.41 per hour or 184 CFM
Constant Mechanical Whole Building Ventilation Rate Specified By ASHRAE 62P: (assumes 60 cfm is also provided by building leakage)	60 cfm

<i>Imbalanced Airflow Required to Pressurize/Depressurize (Approximate)</i>				
322 cfm = 1 pa	505 cfm = 2 pa	657 cfm = 3 pa	792 cfm = 4 pa	916 cfm = 5 pa

<i>Humidification/Dehumidification Requirements (Approximate)</i>		
Added Duct Leakage to Outside	Winter to 35% RH (Add)	Summer to 45% RH (Remove)
None	+21.8 gallons/day	-19.8 gallons/day
50 cfm	+25.4 gallons/day	-25.1 gallons/day
100 cfm	+29.0 gallons/day	-30.5 gallons/day
200 cfm	+36.1 gallons/day	-41.3 gallons/day
300 cfm	+43.2 gallons/day	-52.0 gallons/day

<i>Maximum Acceptable Total Duct Leakage Per New Construction Codes</i>		
Based on Total Air Conditioner Size (5% of 400 cfm/ton):		
1.5 tons: 30 cfm, 6 sq. in.	3.0 tons: 60 cfm, 11 sq. in.	4.0 tons: 80 cfm, 15 sq. in.
2.0 tons: 40 cfm, 8 sq. in.	3.5 tons: 70 cfm, 13 sq. in.	5.0 tons: 100 cfm, 19 sq. in.
2.5 tons: 50 cfm, 9 sq. in.		
Or, if there is no air conditioning, 12.3 square inches (66 cfm) for all the duct systems in the home, based on 3% of conditioned floor space in CFM25		

CFM @ 50 Pa = 4,092 Air changes @ 50 Pa = 9.094 ELA Reference Pressure = 25 Pa
 Infiltrometer 9.0, Copyright Comfort Institute 2000-2003 All Rights Reserved